



**SAWACO**

P.O. Box 5604 , Jeddah 21432, Saudi Arabia.  
Tel: 966(2) 6560084, Fax: 966(2) 6561017.

**سواكو**

ص.ب. 5604 , جدة 21432 , المملكة العربية السعودية.  
هاتف 9662 6560084 فاكس 9662 6561017 .

**LABORATORY**

**WATER ANALYSIS REPORT**

Client : Report :  
Address : S/No. :  
Sampling Place : **Type XII: TDS <5.0 ppm** Date Received:  
Sampling Date : Date Analyzed:

**(A) Principal Constituents**

Cations	mg/L	Detection Unit	Anions	mg/L	Detection Unit
Sodium	0.849	mg/L as Na <sup>1+</sup>	Chloride	0.59	mg/L as Cl <sup>1-</sup>
Calcium	0.000	mg/L as Ca <sup>2+</sup>	Sulfate	0	mg/L as SO <sub>4</sub> <sup>2-</sup>
Magnesium	0.00	mg/L as Mg <sup>2+</sup>	Nitrate	0.0	mg/L as NO <sub>3</sub> <sup>1--N</sup>
Iron	0.0	mg/L as Fe <sup>3+</sup>	Total Alkalinity	1	mg/L as CaCO <sub>3</sub>
Total Hardness	0	mg/L as CaCO <sub>3</sub>			

**(B) Physical Test**

Total Dissolved Solids	1.4	mg/L	pH	6.05	
Conductivity	2.8	uS/cm	Turbidity	0.10	NTU
Foreign Matters	None	None	Free Chlorine	Nil	mg/L as Cl <sub>2</sub>
Color	Clear	None	Odor	No	No
Taste	No	No	Temperature	31.1	° C

**Comments :**

Analyzed by:

  
Quality Control

Noted by:

  
Plant Manager

Approved by: **Mr. Nizar Kammourie**

GM - SAWACO

